



NOTES:

1. REFER TO DRAWING U-1A, SHEET 1 OF 2, FOR ADDITIONAL CONSTRUCTION REQUIREMENTS AND INSTALLATION DETAILS.
2. WHERE THERE IS NO ALTERNATIVE TO PLACING A POLE WITHIN 15- FEET OF THE LEVEE TOE, APPLICANTS MUST SUBMIT A SEEPAGE AND STABILITY ANALYSIS SUPPORTING THE REQUEST. ANALYSIS SHOULD INCLUDE GEOLOGIC BORING LOGS SHOWING THE STRATIFICATION OF SOILS OF THE AREA ADJACENT TO THE PROPOSED POLE LOCATION.



7/2025	new standard	ANB	ANB	ANB	ANB
REV	ISSUE	DWG	DES	CHK	APP

UTILITY POLE
INSTALLATION NOTES

DATE: JAN 2025
DESIGN: ANB
DRAWN: ANB

DRAWING NO.
U-1B
2 of 2